


## 70-S-61 - SPEEDLINE System Data Sheet - Version V1 (24-10-23)

SPEEDLINE 70mm 'C' Stud Partition @600mm Ctrs,  
with 2x Siniat GTEC 12.5mm Fire Board each side



### System Performance Breakdown

Fire Resistance:

BS476 Part 22:1987:

Test Ref & Date or Applied Ref & Report:

Max Height:

Thickness:

Duty Grade: BS 5234: Part 2:1992:

Sound Insulation:

**90/90 Minutes** (Integrity/Insulation).

**BTC 17445F - BRE Report P102396-1011C**

**Refer to Speedline Specification Clause**


**122 mm.** (At Base Track, Excluding Finishes)

**Severe - Annexes A-F**

**45  $R_w$ dB**, Date Tested or Assessed Against - 70-S-57

Test Code:  
**H17533AA**  
Test Date:  
12/08/2011

Freq. Hz	R dB
50	21.0
63	14.9
80	12.6
100	18.5
125	19.5
160	31.9
200	35.0
250	35.0
315	38.1
400	42.1
500	47.0
630	48.0
800	52.7
1 000	54.5
1 250	56.7
1 600	59.7
2 000	59.5
2 500	50.2
3 150	47.5
4 000	49.8
5 000	53.5
6 300	
8 000	
10 000	





Rating according to BS EN ISO 717-1:1997  
Evaluation based on laboratory measurement results obtained by an engineering method.


**$R_w$  (C;Ctr) = 45 (-3;-10) dB**  
Max dev. 9.5 dB at 125 Hz


$C_{50-150}$ = -5 dB	$C_{50-500}$ = -4 dB	$C_{100-5000}$ = -2 dB
$C_{2,50-3,150}$ = -15 dB	$C_{2,50-5,000}$ = -15 dB	$C_{0,100-5000}$ = -10 dB

TESTED AT ONE OF THE UKAS ACCREDITED LABORATORIES BELOW

B.T.C (H-Ref on Graph) 

B.R.E 

AIRO 

S.R.L 

Customer: Metsec plc Hepsec Division

BTC 17533A: Page 8 of 10



SPEEDLINE Drywall Systems, Adsetts House, 16 Europa View, Sheffield Business Park, Sheffield, S9 1XH.

Tel: 0114 231 8030.

Email: [enquiries@speedlinedrywall.co.uk](mailto:enquiries@speedlinedrywall.co.uk)

(As per the requirements set out in ISO/IEC 17025:2017 regarding test data the results stated have been carried out by voestalpine Metsec plc as part of the contract to supply Speedline Metal Sections to SIG Plc)