

CWL507-B-59 - SPEEDLINE CONCRETE SOFFIT CEILING LINER SYSTEM

Type & Ref: Version V1(24/10/23)	
SPEEDLINE Reference:	CWL507-B-59(Conc)
Performance Overview: Fire Resistance (minutes): Sound Insulation: Insulation Required: Soffit Depth: Structural Soffit:	NA. NA R _w dB NA. 20 -175 mm Dependent on bracket type used (background to face of channel). Concrete Soffit
<u>Steel Framing Detail:</u> Perimeter Tracks:	SPEEDLINE SWL60 secured to perimeter of the room, in the centre of the profile at
Liner Section:	600 mm maximum centres with suitable fixings. Install row of SPEEDLINE SWL507 Ceiling Liner Section at 400 mm or 450 mm centres. Fit Liner Section into Perimeter Track at edges.
Brackets:	Fix brackets AH185 (75 mm leg), AH186 (125 mm leg) or AH175 (175 mm leg), to the concrete soffit at maximum 600 mm centres. Secure brackets to Ceiling Liner Section using SPEEDLINE Wafer Head Drywall Screws, one fixing to each side of bracket. Fold back excess bracket to provide flush finish for board lining.
<u>Plasterboard linings:</u>	
Inner Layer: Outer Layer:	 12.5 mm British Gypsum Gyproc SoundBloc attached to underside of framing at 230 mm maximum centres with 25 mm SPEEDLINE Drywall Screws. The perimeter of the room and ends of boards to be fixed at 150 mm maximum centres. 12.5 mm British Gypsum Gyproc SoundBloc attached to underside of framing at
	230 mm maximum centres with 38 mm SPEEDLINE Drywall Screws . The perimeter of the room and ends of boards to be fixed at 150 mm maximum centres.
Humid Areas:	Replace with 12.5 mm British Gypsum Gyproc SoundBloc MR attached to underside of framing at 230 mm maximum centres with 38 mm SPEEDLINE Drywall Screws . The perimeter of the room and ends of boards to be fixed at 150 mm maximum centres.
<u>Finishes:</u> Acoustic Seal:	Skim plaster or taped & jointed (MR Boards to be taped & jointed only). At junctions between partitions and any other air paths, apply a continuous bead of
	SPEEDLINE Intumescent Sealant, to clean dust free surfaces. Please Note: SPEEDLINE Intumescent Sealant is NOT compatible with Lubrizol cPVC pipes.
<u>Accessories:</u> General Notes:	Service Support Plate AH174 & 18 mm Plywood for all pattresses. To be installed in accordance with SPEEDLINE recommendations and relevant British standards including BS 8000-0:2014 and BS 8000-8:2023. This document should be read in conjunction with clauses specified in original contract documentation. Flanking details to be appropriate to current requirements.

SPEEDLINE Drywall Systems, Adsetts House, 16 Europa View, Sheffield Business Park, Sheffield, S9 1XH. Tel: 0114 231 8030.

Email: <u>enquiries@speedlinedrywall.co.uk</u>

⁽As per the requirements set out in ISO/IEC 17025:2017 regarding test data the results stated have been carried out by voestalpine Metsec plc as part of the contract to supply Speedline Metal Sections to SIG Plc)