

**IWL92-B-63(25) - SPEEDLINE INDEPENDENT I STUD WALL LINER**

**Type & Ref:** --  
Version V1(24/10/23) --

**SPEEDLINE Reference:** IWL92-B-63(25)

**Performance Overview:**

Fire Resistance (minutes): NA (Integrity/Insulation) BS 476 Part 22: 1987  
 Sound Insulation: NA R<sub>w</sub>dB  
 Max Height @600mm Ctrs: 4500 mm Calculated on limiting deflection L/240 at 200Pa  
 @400mm Ctrs: 4800 mm  
 @300mm Ctrs: 4900 mm  
 Nominal Width: NA.  
 Insulation Required: 25 mm APR.  
 Duty Rating: Severe. BS 5234-2:1992 (Annexes A-F)  
 Deflection Required: To be confirmed by Structural Engineer.

**Steel Framing Detail:**

Head Tracks: **SPEEDLINE SPT94 'U' Track**, secured to soffit with two rows of suitable fixings at 600 mm centres, staggered by 300 mm to each side of track. (Utilise **SPEEDLINE Deep Flange 'U' Track** if deflection allowance is required)  
 Base Tracks: **SPEEDLINE SPT94 'U' Track**, secured to floor with two rows of suitable fixings at 600 mm centres, staggered by 300 mm to each side of track.  
 Studs: **SPEEDLINE PI92 (92 mm) 'I' Studs** at 600 mm centres. Friction fitted into tracks. (400 mm centres if to be tiled). Abutment 'C' studs secured with two rows of suitable fixings at 600 mm centres, staggered by 300 mm in each side of stud.  
 Deflection Head: If structural deflection is deemed necessary, please refer to **SPEEDLINE Drywall Manual** and/or project detail.

**Plasterboard linings:**

Outer Layer: 15 mm British Gypsum Gyproc DuraLine attached to room side of framing at 300 mm maximum centres with **25 mm SPEEDLINE Drywall Screws**.

Humid Areas: Replace with 15 mm British Gypsum Gyproc DuraLine MR attached to framing at 300 mm maximum centres with **25 mm SPEEDLINE Drywall Screws**.

Boarding Installation: All plasterboard joints to be staggered between layers.

Horizontal Board Joints: **SPEEDLINE PB24** Partition Brace or **FS24** Flat Bracing Strip required behind all horizontal board joints.

**Finishes:** Skim plaster or taped & jointed (MR Boards to be taped & jointed only).

Acoustic Seal: At junctions between partitions and any other air paths, apply a continuous bead of **SPEEDLINE Intumescent Sealant**, to clean dust free surfaces. Please Note: **SPEEDLINE Intumescent Sealant** is NOT compatible with Lubrizol cPVC pipes.

**Accessories:** **Service Support Plate AH174** & 18 mm Plywood for all pattresses.

Electrical socket openings should be considered as part of the fire stopping package and consideration should be given to meet the performances of the Partition/Lining system regarding fire and acoustic performance.

**General Notes:** To be installed in accordance with SPEEDLINE recommendations and relevant British standards including BS 8000-0:2014 and BS 8000-8:2023.

This document should be read in conjunction with clauses specified in original contract documentation. Flanking details to be appropriate to current requirements.

---

SPEEDLINE Drywall Systems, Adsetts House, 16 Europa View, Sheffield Business Park, Sheffield, S9 1XH.

Tel: 0114 231 8030.

Email: [enquiries@speedlinedrywall.co.uk](mailto:enquiries@speedlinedrywall.co.uk)

(As per the requirements set out in ISO/IEC 17025:2017 regarding test data the results stated have been carried out by voestalpine Metsec plc as part of the contract to supply Speedline Metal Sections to SIG Plc)