

IWL70-K-60(50) - SPEEDLINE INDEPENDENT I STUD WALL LINER

Type & Ref: --
 Version V1(24/10/23) --

SPEEDLINE Reference: IWL70-K-60(50)

Performance Overview:

Fire Resistance (minutes): NA (Integrity/Insulation) BS 476 Part 22: 1987
 Sound Insulation: NA R_wdB
 Max Height @600mm Ctrs: 3900 mm Calculated on limiting deflection L/240 at 200Pa
 @400mm Ctrs: 4500 mm
 @300mm Ctrs: 4800 mm
 Nominal Width: NA.
 Insulation Required: 50 mm APR.
 Duty Rating: Severe. BS 5234-2:1992 (Annexes A-F)
 Deflection Required: To be confirmed by Structural Engineer.

Steel Framing Detail:

Head Tracks: **SPEEDLINE SPT72 'U' Track**, secured to soffit, in the centre of the profile at 600 mm centres with suitable fixings. (Utilise **SPEEDLINE Deep Flange 'U' Track** if deflection allowance is required)
 Base Tracks: **SPEEDLINE SPT72 'U' Track**, secured to floor in the centre of the profile, with suitable fixings.
 Studs: **SPEEDLINE PI70 (70 mm) 'I' Studs** at 600 mm centres. Friction fitted into tracks. (400 mm centres if to be tiled). Abutment 'C' studs secured at max 600 mm centres, with suitable fixings.
 Deflection Head: If structural deflection is deemed necessary, please refer to **SPEEDLINE Drywall Manual** and/or project detail.

Plasterboard linings:

Inner Layer: 15 mm Knauf Soundshield Plus attached to room side of framing at 600 mm maximum centres with **25 mm SPEEDLINE Drywall Screws**.
 Outer Layer: 15 mm Knauf Soundshield Plus attached to room side of framing at 300 mm maximum centres with **42 mm SPEEDLINE Drywall Screws**.
 Humid Areas: Replace with 15 mm Knauf Performance Plus attached to framing at 300 mm maximum centres with **42 mm SPEEDLINE Drywall Screws**.
 Boarding Installation: All plasterboard joints to be staggered between layers.
 Horizontal Board Joints: **SPEEDLINE PB24** Partition Brace or **FS24** Flat Bracing Strip required behind all horizontal board joints.

Finishes:

Acoustic Seal: Skim plaster or taped & jointed (MR Boards to be taped & jointed only).
 At junctions between partitions and any other air paths, apply a continuous bead of **SPEEDLINE Intumescent Sealant**, to clean dust free surfaces. Please Note: **SPEEDLINE Intumescent Sealant** is NOT compatible with Lubrizol cPVC pipes.

Accessories:

Service Support Plate AH174 & 18 mm Plywood for all pattresses.
 Electrical socket openings should be considered as part of the fire stopping package and consideration should be given to meet the performances of the Partition/Lining system regarding fire and acoustic performance.

General Notes:

To be installed in accordance with SPEEDLINE recommendations and relevant British standards including BS 8000-0:2014 and BS 8000-8:2023.

This document should be read in conjunction with clauses specified in original contract documentation. Flanking details to be appropriate to current requirements.