

## 50-S-56 - SPEEDLINE METAL STUD PARTITION

**Type & Ref:** --  
 Version V1(24/10/23) --

**SPEEDLINE Reference:** 50-S-56

### **Performance Overview:**

Fire Resistance (minutes): 60/60 (Integrity/Insulation) BS 476 Part 22: 1987  
 Sound Insulation: NA  $R_{w,dB}$   
**Maximum Height:** Calculated on limiting deflection L/240 at 200Pa  
 @ 600 mm Ctrs: 2800 mm  
 @ 400 mm Ctrs: 3100 mm  
 @ 300 mm Ctrs: 3200 mm  
 Nominal Width: 82 mm. (Excluding finishes).  
 Insulation Required: NA.  
 Duty Rating: Heavy. BS 5234-2:1992 (Annexes A-F)  
 Deflection Required: To be confirmed by Structural Engineers. (Max 25mm on 50mm studs)

### **Steel Framing Detail:**

Head Tracks: All as per the current **SPEEDLINE** Drywall Manual.  
**SPEEDLINE SPT52 'U' Track**, secured to soffit, in the centre of the profile at 600 mm centres with suitable fixings. (Utilise **SPEEDLINE Deep Flange 'U' Track** if deflection allowance is required)  
 Base Tracks: **SPEEDLINE SPT52 'U' Track**, secured to floor in the centre of the profile, with suitable fixings.  
 Studs: **SPEEDLINE SPS50 'C' Studs** at 600 mm centres. Friction fitted into tracks. (400 mm centres if to be tiled). Abutment 'C' studs secured at max 600 mm centres, with suitable fixings.  
 Deflection Head: If structural deflection is deemed necessary, please refer to **SPEEDLINE** Drywall Manual and/or project detail.

### **Plasterboard linings:**

Outer Layer: 15 mm Siniat GTEC Fire Board attached to both sides of framing at 300 mm maximum centres with **25 mm SPEEDLINE Drywall Screws**.  
 Humid Areas: Replace with 15 mm Siniat GTEC Fire MR Board attached to framing at 300 mm maximum centres with **25 mm SPEEDLINE Drywall Screws**.  
 Boarding Installation: All plasterboard joints to be staggered on opposing partition faces.  
 Horizontal Board Joints: **SPEEDLINE PB24** Partition Brace or **FS24** Flat Bracing Strip required behind all horizontal board joints.

### **Finishes:**

Acoustic Seal: Skim plaster or taped & jointed (MR Boards to be taped & jointed only).  
 At junctions between partitions and any other air paths, apply a continuous bead of **SPEEDLINE Intumescent Sealant**, to clean dust free surfaces. Please Note: **SPEEDLINE Intumescent Sealant** is NOT compatible with Lubrizol cPVC pipes.

### **Accessories:**

**Service Support Plate AH174** & 18 mm Plywood for all pattresses.  
 Electrical socket openings should be considered as part of the fire stopping package and consideration should be given to meet the performances of the Partition/Lining system regarding fire and acoustic performance.

**General Notes:**

To be installed in accordance with SPEEDLINE recommendations and relevant British standards including BS 8000-0:2014 and BS 8000-8:2023.

This document should be read in conjunction with clauses specified in original contract documentation. Flanking details to be appropriate to current requirements.